



**PRODUCT NUMBER: 2092012**  
**ELECTROSOFT COMPOSITE**  
**Class 00**

For electrical work with a maximum voltage of 500 volts.  
 Can be used without overglove.



**Overview**

**Reference Number**

2092012

**Product Type**

Gloves

**Range**

Electrical Protection

**Line**

Composite

**Brand**

Honeywell

**Brand formerly known as**

ELECTROSOFT

**Industry**

- Administration
- Energy or Electricity
- Maintenance
- Telecoms
- Utilities

**Product Use**

For electrical work with a maximum voltage of 500 volts. Can be used without overglove.

**Features & Benefits**

**Feature**

Natural latex insulating glove on cotton base  
 Outside in orange polychloroprene  
 RC Category, with Mechanical protection

**Benefit**

**COMFORT**

Its dielectric natural latex composition on flocked interior base makes it very comfortable.  
 Product appreciated for its long last and precision.  
 Its patterned finish gives it a highly appreciated grip in damp conditions.

**RESISTANCE**

The outer orange elastomer layer provides excellent mechanical resistance.  
Its anatomical shape makes flexing easier while ensuring a high level of protection.

**SAFETY**

It can be used without a leather overglove as it has been combined with a mechanically more resistant elastomer.

**Technical Description**

**Description**

CE CATEGORY : III Irreversible risks  
In accordance with standards :  
EN 60903-2003  
CEI 903-2002

**CHARACTERISTICS :**

Natural latex insulating glove on cotton base  
Outside in orange polychloroprene  
Class 00  
RC Category, with Mechanical protection

**Product Technology**

Dipped Gloves

**Glove/liner color**

Orange

**Coating Type**

Latex, cotton and polychloroprene

**Length**

36 cm

**Thickness**

1,8 mm

**Harmlessness**

In conformity with European standards

**Sizes**

7 to 11

**Packaging Label**

**Tagging**

CE HONEYWELL  
2092012 XX  
EN 60903-2003  
CEI 903-2002

**Certifications**

**EC Category PPE**

3

**EC Certificate Number**

7015

**EC Attestation**

EC Attestation

**EC Attestation Number**

7015

**Additional Information**

**User Information Sheet**

On the polybag

## Maintenance

### Life Cycle

Gloves that are used frequently should be tested at intervals less than 6 month.

Gloves that are used only occasionally should be tested after each use and, in any case, at intervals of not more than 12 months.

Gloves held in stock should be retested at intervals not exceeding 12 months.

### Storage Information

Store in original packaging (Opaque and antiUV packaging used for protection and instructions for use).

Do not compact or fold.

Do not expose to heat sources (sunlight, radiators, artificial light).

Store between 10°C and 21°C.

### Care Instructions

**Inspection** : Before each use, carry out a visual inspection and check the glove inflation. Any puncture or perforation makes the gloves unusable.

**Precautions** : Do not expose to solvents or chemicals that may cause deterioration. Do not use the glove when damp.

**Cleaning** : use water and soap. Dry below 65°C with ambient humidity.